


Exxon Requirements to
API Standard 607 Fourth Edition
Fire Test Report

Performed for

SGL Technic Inc.
Polycarbon Division



Sigraflex Hochdruck
6 inch Class 300 Gaskets
Project Number: 20292
February 2003



Performed by

YARMOUTH RESEARCH AND TECHNOLOGY

92 East Elm Street
Yarmouth, ME 04096 USA
(207) 829-5359
yrtlab@maine.rr.com
www.yarmouthresearch.com

Yarmouth Research and Technology

Exxon Additional Requirements to API 607 4th Edition Fire Test

| | |
|--|-----------------------------|
| Customer: SGL Technic Inc. -Polycarbon Div. | Date: 2/4/2003 |
| Project Number: PN20292 | |
| Specification: Exxon additional requirements to API 607 4th Edition | |
| Product Code: Sigraflex Hochdruck | |
| Gasket Thickness: 0.063 inches | |
| Flange Mfgr: Weldbend | Nut Mfgr: Shih Hsang |
| Bolt Mfgr: Alloy & Stainless Fasteners VA | |
| Comments: 0 | |
| YRT Technician: Matthew J. Wasielewski, P.E. | |

Bolt Torques (ft-lbs)

| Bolt Location | At Start of Test | Before Adjustments | At Test Completion |
|---------------|------------------|--------------------|--------------------|
| Upstream #1 | 200 | 40 | 200 |
| Upstream #2 | 200 | 40 | 200 |
| Upstream #3 | 200 | 55 | 200 |
| Upstream #4 | 200 | 50 | 200 |
| Downstream #1 | 200 | 50 | 200 |
| Downstream #2 | 200 | 50 | 200 |
| Downstream #3 | 200 | 70 | 200 |
| Downstream #4 | 200 | 25 | 200 |

Post Burn Leakage Tests

Maximum allowable combined leakage: 150 ml/min

| Test Pressure (psig) | Side A Leak Rate (ml/min) | Side B Leak Rate (ml/min) | Total Leak Rate (ml/min) | Flange Bolt Retorques |
|-------------------------|------------------------------|------------------------------|-----------------------------|--------------------------|
| 30 | 20 | 96 | 116 | |
| 50 | 10 | 442 | 452 | Yes, Side B |
| 100 | 724 | 0 | 724 | Yes, Side A |
| 200 | 0 | 0 | 0 | |
| 300 | 0 | 0 | 0 | |
| 700 | 0 | 0 | 0 | |

Witnesses

Matthew J. Wasielewski



Yarmouth Research and Technology

Post Burn Test Information

Customer: SGL Technic Inc. -Polycarbon Div.

Date: 2/4/2003

Product Code: Sigraflex Hochdruck

Project Number: PN20292

Test Pressure: 30

Raw Data

| Time | Pressure (psig) | Flange 1 Temp - F | Flange 2 Temp - F | Flange 3 Temp - F | Flange 4 Temp - F |
|----------|--------------------|----------------------|----------------------|----------------------|----------------------|
| 11:21:53 | 30 | 105 | 111 | 117 | 113 |
| 11:22:08 | 30 | 105 | 111 | 118 | 113 |
| 11:22:23 | 30 | 105 | 111 | 118 | 113 |
| 11:22:38 | 30 | 105 | 111 | 118 | 113 |
| 11:22:53 | 30 | 105 | 111 | 118 | 113 |
| 11:23:08 | 30 | 105 | 111 | 118 | 113 |
| 11:23:23 | 30 | 105 | 112 | 118 | 113 |
| 11:23:38 | 30 | 105 | 112 | 118 | 113 |
| 11:23:53 | 30 | 105 | 112 | 118 | 113 |
| 11:24:08 | 30 | 105 | 112 | 118 | 113 |
| 11:24:23 | 30 | 105 | 112 | 118 | 113 |
| 11:24:38 | 30 | 105 | 112 | 118 | 113 |
| 11:24:53 | 30 | 105 | 112 | 118 | 113 |
| 11:25:08 | 30 | 105 | 112 | 118 | 113 |
| 11:25:23 | 30 | 105 | 112 | 118 | 113 |
| 11:25:38 | 30 | 105 | 112 | 118 | 113 |
| 11:25:53 | 30 | 105 | 112 | 118 | 113 |
| 11:26:08 | 30 | 105 | 112 | 118 | 113 |
| 11:26:23 | 30 | 106 | 112 | 118 | 113 |
| 11:26:38 | 30 | 105 | 112 | 118 | 113 |
| 11:26:53 | 30 | 106 | 112 | 118 | 113 |

| | | |
|--|-----|--------|
| Leakage Collected from Upstream Flange Gasket A: | 100 | mls |
| Average Leak Rate Over 5 Minute Duration: | 20 | ml/min |
| Leakage Collected from Downstream Flange Gasket B: | 480 | mls |
| Average Leak Rate Over 5 Minute Duration: | 96 | ml/min |
| Were Both Flange Leakages Below 150 ml/min? | Yes | |

Yarmouth Research and Technology

Post Burn Test Information

Customer: SGL Technic Inc. -Polycarbon Div.

Date: 2/4/2003

Product Code: Sigraflex Hochdruck

Project Number: PN20292

Test Pressure: 50

Raw Data

| Time | Pressure (psig) | Flange 1 Temp - F | Flange 2 Temp - F | Flange 3 Temp - F | Flange 4 Temp - F |
|----------|--------------------|----------------------|----------------------|----------------------|----------------------|
| 11:35:06 | 51 | 104 | 110 | 111 | 109 |
| 11:35:21 | 50 | 104 | 110 | 111 | 109 |
| 11:35:36 | 50 | 104 | 110 | 110 | 109 |
| 11:35:51 | 50 | 104 | 110 | 110 | 109 |
| 11:36:06 | 50 | 104 | 110 | 110 | 108 |
| 11:36:21 | 50 | 104 | 109 | 110 | 108 |
| 11:36:36 | 50 | 104 | 109 | 109 | 108 |
| 11:36:51 | 49 | 104 | 109 | 109 | 108 |
| 11:37:06 | 49 | 104 | 109 | 109 | 108 |
| 11:37:21 | 49 | 104 | 109 | 108 | 107 |
| 11:37:36 | 49 | 104 | 109 | 108 | 107 |
| 11:37:51 | 49 | 103 | 108 | 108 | 107 |
| 11:38:06 | 49 | 103 | 108 | 108 | 107 |
| 11:38:21 | 49 | 103 | 108 | 107 | 107 |
| 11:38:36 | 50 | 103 | 108 | 107 | 106 |
| 11:38:51 | 51 | 103 | 108 | 107 | 106 |
| 11:39:06 | 51 | 103 | 108 | 107 | 106 |
| 11:39:21 | 50 | 103 | 107 | 106 | 106 |
| 11:39:36 | 50 | 103 | 107 | 106 | 106 |
| 11:39:51 | 50 | 103 | 107 | 106 | 106 |
| 11:40:06 | 50 | 103 | 107 | 106 | 105 |

| | | |
|--|------|--------|
| Leakage Collected from Upstream Flange Gasket A: | 49 | mls |
| Average Leak Rate Over 5 Minute Duration: | 9.8 | ml/min |
| | | |
| Leakage Collected from Downstream Flange Gasket B: | 2210 | mls |
| Average Leak Rate Over 5 Minute Duration: | 442 | ml/min |
| | | |
| Were Both Flange Leakages Below 150 ml/min? | No | |

Yarmouth Research and Technology

Post Burn Test Information

Customer: SGL Technic Inc. -Polycarbon Div.

Date: 2/4/2003

Product Code: Sigraflex Hochdruck

Project Number: PN20292

Test Pressure: 100

Raw Data

| Time | Pressure (psig) | Flange 1 Temp - F | Flange 2 Temp - F | Flange 3 Temp - F | Flange 4 Temp - F |
|----------|--------------------|----------------------|----------------------|----------------------|----------------------|
| 12:03:23 | 100 | 77 | 93 | 93 | 77 |
| 12:03:38 | 100 | 77 | 93 | 93 | 77 |
| 12:03:53 | 100 | 77 | 93 | 93 | 77 |
| 12:04:08 | 100 | 77 | 92 | 93 | 77 |
| 12:04:23 | 100 | 77 | 92 | 93 | 77 |
| 12:04:38 | 101 | 77 | 92 | 92 | 77 |
| 12:04:53 | 100 | 77 | 92 | 92 | 77 |
| 12:05:08 | 100 | 77 | 92 | 92 | 77 |
| 12:05:23 | 100 | 77 | 92 | 92 | 78 |
| 12:05:38 | 101 | 77 | 92 | 92 | 79 |
| 12:05:53 | 100 | 77 | 92 | 92 | 79 |
| 12:06:08 | 100 | 77 | 92 | 92 | 79 |
| 12:06:23 | 100 | 77 | 92 | 92 | 79 |
| 12:06:38 | 100 | 77 | 92 | 92 | 79 |
| 12:06:53 | 100 | 77 | 92 | 92 | 79 |
| 12:07:08 | 100 | 77 | 92 | 92 | 79 |
| 12:07:23 | 100 | 77 | 92 | 92 | 79 |
| 12:07:38 | 100 | 76 | 92 | 92 | 79 |
| 12:07:53 | 100 | 76 | 92 | 92 | 79 |
| 12:08:08 | 100 | 76 | 92 | 92 | 78 |
| 12:08:23 | 100 | 76 | 92 | 92 | 78 |

| | | |
|--|------|--------|
| Leakage Collected from Upstream Flange Gasket A: | 3620 | mls |
| Average Leak Rate Over 5 Minute Duration: | 724 | ml/min |
| | | |
| Leakage Collected from Downstream Flange Gasket B: | 0 | mls |
| Average Leak Rate Over 5 Minute Duration: | 0 | ml/min |
| | | |
| Were Both Flange Leakages Below 150 ml/min? | No | |

Yarmouth Research and Technology

Post Burn Test Information

Customer: SGL Technic Inc. -Polycarbon Div.

Date: 2/4/2003

Product Code: Sigraflex Hochdruck

Project Number: PN20292

Test Pressure: 200

Raw Data

| Time | Pressure (psig) | Flange 1 Temp - F | Flange 2 Temp - F | Flange 3 Temp - F | Flange 4 Temp - F |
|----------|--------------------|----------------------|----------------------|----------------------|----------------------|
| 12:33:53 | 201 | 72 | 88 | 88 | 72 |
| 12:34:08 | 201 | 72 | 88 | 88 | 72 |
| 12:34:23 | 201 | 72 | 88 | 88 | 72 |
| 12:34:38 | 200 | 72 | 87 | 88 | 72 |
| 12:34:53 | 200 | 72 | 87 | 88 | 72 |
| 12:35:08 | 200 | 72 | 87 | 87 | 72 |
| 12:35:23 | 200 | 72 | 87 | 87 | 72 |
| 12:35:38 | 200 | 72 | 87 | 87 | 72 |
| 12:35:53 | 200 | 72 | 87 | 87 | 73 |
| 12:36:08 | 200 | 72 | 87 | 87 | 74 |
| 12:36:23 | 200 | 72 | 87 | 87 | 74 |
| 12:36:38 | 200 | 72 | 87 | 87 | 74 |
| 12:36:53 | 200 | 72 | 87 | 87 | 74 |
| 12:37:08 | 200 | 72 | 87 | 87 | 74 |
| 12:37:23 | 200 | 72 | 87 | 87 | 74 |
| 12:37:38 | 200 | 72 | 87 | 87 | 74 |
| 12:37:53 | 200 | 72 | 87 | 87 | 74 |
| 12:38:08 | 200 | 71 | 87 | 87 | 74 |
| 12:38:23 | 200 | 71 | 87 | 87 | 74 |
| 12:38:38 | 200 | 71 | 87 | 87 | 73 |
| 12:38:53 | 200 | 71 | 87 | 87 | 73 |

| | | |
|--|-----|--------|
| Leakage Collected from Upstream Flange Gasket A: | 0 | mls |
| Average Leak Rate Over 5 Minute Duration: | 0 | ml/min |
| | | |
| Leakage Collected from Downstream Flange Gasket B: | 0 | mls |
| Average Leak Rate Over 5 Minute Duration: | 0 | ml/min |
| | | |
| Were Both Flange Leakages Below 150 ml/min? | Yes | |

Yarmouth Research and Technology

Post Burn Test Information

Customer: SGL Technic Inc. -Polycarbon Div.

Date: 2/4/2003

Product Code: Sigraflex Hochdruck

Project Number: PN20292

Test Pressure: 300

Raw Data

| Time | Pressure (psig) | Flange 1 Temp - F | Flange 2 Temp - F | Flange 3 Temp - F | Flange 4 Temp - F |
|----------|--------------------|----------------------|----------------------|----------------------|----------------------|
| 12:46:41 | 300 | 71 | 86 | 86 | 73 |
| 12:46:56 | 300 | 71 | 86 | 86 | 73 |
| 12:47:11 | 300 | 71 | 86 | 86 | 73 |
| 12:47:26 | 300 | 71 | 86 | 86 | 73 |
| 12:47:41 | 300 | 71 | 86 | 86 | 73 |
| 12:47:56 | 300 | 71 | 86 | 86 | 72 |
| 12:48:11 | 300 | 71 | 86 | 86 | 72 |
| 12:48:26 | 300 | 71 | 86 | 86 | 72 |
| 12:48:41 | 300 | 71 | 86 | 86 | 72 |
| 12:48:56 | 300 | 71 | 86 | 86 | 72 |
| 12:49:11 | 300 | 71 | 86 | 86 | 72 |
| 12:49:26 | 300 | 71 | 86 | 86 | 72 |
| 12:49:41 | 300 | 71 | 86 | 86 | 72 |
| 12:49:56 | 299 | 71 | 86 | 86 | 72 |
| 12:50:11 | 299 | 71 | 86 | 86 | 72 |
| 12:50:26 | 299 | 71 | 86 | 86 | 72 |
| 12:50:41 | 299 | 71 | 86 | 86 | 72 |
| 12:50:56 | 299 | 70 | 86 | 86 | 72 |
| 12:51:11 | 299 | 70 | 86 | 86 | 72 |
| 12:51:26 | 299 | 70 | 86 | 86 | 72 |
| 12:51:41 | 299 | 70 | 86 | 86 | 72 |

| | | |
|--|-----|--------|
| Leakage Collected from Upstream Flange Gasket A: | 0 | mls |
| Average Leak Rate Over 5 Minute Duration: | 0 | ml/min |
| | | |
| Leakage Collected from Downstream Flange Gasket B: | 0 | mls |
| Average Leak Rate Over 5 Minute Duration: | 0 | ml/min |
| | | |
| Were Both Flange Leakages Below 150 ml/min? | Yes | |

Yarmouth Research and Technology

Post Burn Test Information

Customer: SGL Technic Inc. -Polycarbon Div.

Date: 2/4/2003

Product Code: Sigraflex Hochdruck

Project Number: PN20292

Test Pressure: 700

Raw Data

| Time | Pressure (psig) | Flange 1 Temp - F | Flange 2 Temp - F | Flange 3 Temp - F | Flange 4 Temp - F |
|----------|--------------------|----------------------|----------------------|----------------------|----------------------|
| 12:57:22 | 701 | 70 | 85 | 86 | 72 |
| 12:57:37 | 701 | 70 | 85 | 86 | 72 |
| 12:57:52 | 700 | 70 | 85 | 86 | 72 |
| 12:58:07 | 700 | 71 | 85 | 86 | 72 |
| 12:58:22 | 700 | 71 | 85 | 86 | 72 |
| 12:58:37 | 700 | 71 | 85 | 86 | 72 |
| 12:58:52 | 699 | 71 | 85 | 86 | 72 |
| 12:59:07 | 699 | 71 | 85 | 86 | 72 |
| 12:59:22 | 699 | 71 | 85 | 86 | 72 |
| 12:59:37 | 699 | 71 | 85 | 86 | 72 |
| 12:59:52 | 698 | 71 | 85 | 86 | 72 |
| 13:00:07 | 698 | 71 | 85 | 86 | 72 |
| 13:00:22 | 698 | 71 | 85 | 86 | 72 |
| 13:00:37 | 698 | 71 | 85 | 85 | 72 |
| 13:00:52 | 698 | 71 | 85 | 85 | 72 |
| 13:01:07 | 698 | 71 | 85 | 85 | 72 |
| 13:01:22 | 698 | 71 | 85 | 85 | 72 |
| 13:01:37 | 698 | 71 | 85 | 85 | 72 |
| 13:01:52 | 698 | 71 | 85 | 85 | 72 |
| 13:02:07 | 698 | 71 | 85 | 85 | 73 |
| 13:02:22 | 698 | 71 | 85 | 85 | 73 |

| | | |
|--|-----|--------|
| Leakage Collected from Upstream Flange Gasket A: | 0 | mls |
| Average Leak Rate Over 5 Minute Duration: | 0 | ml/min |
| | | |
| Leakage Collected from Downstream Flange Gasket B: | 0 | mls |
| Average Leak Rate Over 5 Minute Duration: | 0 | ml/min |
| | | |
| Were Both Flange Leakages Below 150 ml/min? | Yes | |

ATTACHMENT II

EXXON FIRETEST PROCEDURES FOR PIPE GASKETS

Revision Date: February, 1995

A) GENERAL

- The fire test will consist of a modified API-607 Fourth Edition firetest.
- The fire test will require at least 3 flange thermocouples to reach 1200°F for 15 minutes. See Figure 1 for thermocouple locations.

B) INSTALLATION PROCEDURES:

- The gasket shall be installed between two 6" - raised face ANSI 300 flanges (see Attachment II, Page 2).
- 3/4" B7 bolts and 2H nuts shall be used torqued to 60% of yield (200 ft/lbs).
- Thermocouples shall be installed in upstream flanges at the 9 o'clock position, and downstream flanges at the 3 o'clock position as shown in Figure 1.
- Hydro at 110%. No leaks allowed. If a leak occurs, the test is terminated.
- The test flanges may only be used once if a firetests and the manufacturer shall be approved by Exxon.


C) FIRETEST:

- Heat up, cool down, duration and leak testing (except as modified below) shall follow API-607 Fourth Edition.
- Observe and record any leakage during firetest and cooldown.
- Perform leakage tests as follows after cooldown:
 - + Pressure levels are: 30, 50, 100, 200, 300, and 700 psig.
 - + Allowable leakage rates: For 30 psig tests = 150 ml/min maximum (25 ml/min/inch)
 - + Note at what pressure 150 ml/min is exceeded (pressure A). Reduce pressure to zero psig and measure the "after leak test" bolt torques. Increase the pressure again to pressure A and try to stop the leak by tightening the bolts.

D) Dismantle, take pictures, and make note of condition of gasket in reports.



Note: This test verifies gaskets for refinery services only up to ANSI 300 class, due to the low pressure testing performed.

Note: Thermocouples 1, 2, 3, and 4 are welded to the flange. Thermocouples 5 and 6 are for flame temperature located 1" away from flange thermocouples respectively.



INSTALLATION, LUBRICATING, AND TORQUING PROCEDURES
FOR EXXON FIRE TEST FOR GASKETS

1. Make sure studs, nuts, and flange surfaces which will be in contact with the nuts are free from burrs and debris. Flange raised face surface finish shall be per ASME B16.5 para. 6.4.4.1 or equivalent. No radial grooves or similar damage in the sealing area of the gasket is allowed. New ASTM A193 B-7 studs and ASTM A194, 2H nuts shall be used for each firetest. The test shall consist of two 6" Class 300 flange joints in conformance with ASME B16.5 and made of ASTM A-105 material
2. Coat entire surface of each stud with Anti-Seize.
3. Cover coat the flange nut bearing surface around each bolt hole with a coating of Anti-Seize.
4. Install bolt numbers (10, 6, 2, 11, and 7) and place the gasket between the flange faces. See Figure 2.
5. Install the remaining studs and nuts and tighten finger tight.
6. Using a calibrated torque wrench, torque the 3/4" B-7 studs in the sequence provided in Figure 2.
 - a) to 50 ft-lbs. (outboard nuts)
 - b) to 100 ft-lbs. (outboard nuts)
 - c) to 150 ft-lbs. (outboard nuts)
 - d) to 200 ft-lbs. (inboard nuts)
7. A bolt-to-bolt torque check is required to even out bolt stresses. One revolution is required per the bolt sequence shown in Figure 3. Perform this tightening on the inboard nuts. Torque to 200 ft-lbs.
8. Repeat step 7 but on the "outboard" nuts.
9. Check final torque on the outboard nuts at 1, 2, 3, and 4 and record. See Figure 2. (The target torque is minimum 185 ft-lbs, maximum 215 ft-lbs. Nuts shall not be loosened if 215 ft-lbs is exceeded.)





To: W.L. BLAKE COMPANY
 366 WEST COMMERCIAL ST.
 PORTLAND, ME 04102
 Attn: HOLLY




**MATERIAL TEST REPORT
 FLANGES**

6600 South Harlem Avenue
 Argo, IL 60501-1930
 Phone: (708) 594-1700
 Fax: (708) 458-0106

| Description | Steel Producer | | | | | | | | | | | | | | | |
|-----------------------------------|----------------|------|------|------|------|------|------|------|------|------|-------|-------|-------|-------|-----|-----|
| | Heat I | S | P | Ma | C | Cu | NI | Cr | Mo | Cb | V | Ten | Yield | Elong | RO | BHN |
| Qty | | | | | | | | | | | | | | | | |
| Carbon Equivalence Notes: | | | | | | | | | | | | | | | | |
| 8" Class 300 Welding Neck StdB RF | PBC | .015 | .009 | .040 | .200 | .090 | .110 | .020 | .000 | .025 | 86300 | 58700 | 28.40 | 57.50 | 187 | |
| 0.390 | | | | | | | | | | | | | | | | |
| 6" Class 300 Blind RF | OWZ | .020 | .034 | .050 | .260 | .160 | .080 | .035 | .000 | .002 | 80400 | 55600 | 31.00 | 60.30 | 174 | |
| 0.393 | | | | | | | | | | | | | | | | |

By: *[Signature]* January 17, 2003
 Quality Assurance Department
 Test Results herein are correct as contained in test records retained by the company.
 In accordance with EN 10 204 Para 3.4 B



Meets the requirements of ASTM A-105, (and SA-105).
 ISO 9002 CERTIFIED MANUFACTURER
 All flanges meet NACE MR0-175 - Latest Revision

ALLOY & STAINLESS FASTENERS VA

* C E R T I F I C A T E *
* O F T E S T *

VIRGINIA - 757-427-0111
PENNSYLVANIA -215-628-9598
VA FAX 757-427-2305
PA 215-628-0670

Att: Matt

TO: K. L. JACK & CO.
145 WARREN AVE.
PORTLAND, ME 04103

Customer P/O # T37224

Our Order # 193936

| ITEM QUANTITY DESCRIPTION | | | LOT | | |
|---|---------------|---------------|------------|-----------|---------|
| 2 110 EA 3/4-10 x 4 1/2 HEAVY HEX BOLT ASTM A193 B7 | | | 33855 | | |
| ASTM SPEC DATE: 95 | | | | | |
| TEMPERING TEMP: 650 DEG C | | | | | |
| WEDGE TENSILE 131700 | | | | | |
| MERCURY FREE AND NO WELD | | | CARBON | MANGANESE | |
| | | | .43 | .88 | |
| Heat No. | TENSILE (PSI) | YIELD (PSI) | PHOSPHORUS | SULFUR | SILICON |
| 2M392 | 132500 | 119000 | .021 | .009 | .22 |
| ELONGATION | RED. OF AREA | HARDNESS (HB) | CHROMIUM | MOLY. | |
| 19.0 | 58.0 | 277 | .94 | .17 | |
| MACRO ETCH | | | | | |
| S1/R1/C1 | | | | | |

Date: 01/20/03

We hereby certify that the foregoing data is a true copy of the data furnished to us
by the producing mill.

ALLOY & STAINLESS FASTENERS VA
Please call our office if you require a
signed certificate of test.

01/21/03 14:46

630 588 9344

HTI-QUALITY CHGO

008



SHIH HSANG YWA INDUSTRIAL CO., LTD.



ISO 9002
B S M I
7M4Y025

134, SHIN-LO STREET, KANGSHAN 82001 KAOHSIUNG, TAIWAN R. O. C.
TEL : (07)6212286 FAX : (07)6222273 E mail : shyindco@ms5.hinet.net

F 0 2 9
VALID : FEB.29.2004

VALID : APRIL 11 2002

CERTIFICATE OF INSPECTION

NAME OF CUST : HEADS AND THREADS COMPANY
 ADDRESS OF CUST : 200 KENNDY DRIVE, SAYREVILLE, NEW JERSEY 08872, USA
 COMMODITY : ANSI B18.2.2 ASTM A194 GR-2H HEX HEAVY S.C.W. NUT
 <MFG ID&2H> HT&PLN
 PACKING LIST NO : S01070194 PO#107062/05/18/2001 ISSUE DATE : 08/06/2001
 MATERIAL TYPE : 1045SK LOT NO. : W801-170703AM1
 SAMPLE SIZE : ACC. TO ASME B18.18.2M-87 CERT. NO. : 01080072
 MANU. DATE : 07/21/2001 HEAT NO. : 3F707
 MANUFACTURER : SHIH HSANG YWA COMP. SIZE : 3/4 -10
 ADDRESS : SAME AS LAB LOT SIZE : 45,000 PCS

DIMENSIONAL INSPECTIONS SPECIFICATION:ASME/ANSI B18.2.2-87

INSPECTOR:/QC SAMPLER :/QC TEST DATE:07/31/2001

| CHARACTERISTICS | TEST METHOD | SPECIFIED | ACTUAL RESULT | ACC. | REJ |
|-----------------|-----------------|----------------|----------------|------|-----|
| APPEARANCE | ASTM F812-97 | | PASSED | 100 | 0 |
| ACROSS FLATS | | 30.79-31.75 mm | 30.93-31.17 mm | 32 | 0 |
| THREAD | ASME B1.1-89 2B | | PASSED | 32 | 0 |
| HEIGHT | | 18.03-19.25 mm | 18.46-18.62 mm | 8 | 0 |
| MARK | Φ 2H | | PASSED | 100 | 0 |

MECHANICAL PROPERTIES SPECIFICATION:ASTM A194-00 GR-2H

INSPECTOR:J.L.HSIEH/QC SAMPLER :J.L.HSIEH/QC TEST DATE:07/31/2001

| CHARACTERISTICS | TEST METHOD | SPECIFIED | ACTUAL RESULT | ACC. | REJ |
|---|--------------|----------------|-----------------|------|-----|
| HARDNESS | ASTM E18-98 | 24-38 HRC | 29.5-31.0 HRC | 8 | 0 |
| PROOF LOAD | ASTM F606-98 | MIN 175000 PSI | MIN 175000 PSI | 5 | 0 |
| DECARBURIZATION | SAE J121-97 | | PASSED | 1 | 0 |
| HARDNESS AFTER 24H AT 540CASTM A194MIN 89 HRB | | | 100.6-103.2 HRB | 5 | 0 |

INSPECTION RESULT:SAMPLES TESTED CONFORM TO ALL OF THE STANDARD LISTED ABOVE.

LAB. CHIEF/CERT. SIGNER: James Yu (JAMES YU) PAGE: 1 OF 1
 *ACCREDITED BY BSMI ISO 9002 1996 (CNS 12682) 7M4Y025-01; VALID TO APRIL 11 2002
 *SHIH HSANG YWA Q.C DEP. OPERATES INDEPENDENTLY OF THE MANUFACTURING DEP.
 *THE RESULTS RELATE ONLY TO THE ITEMS TESTED.
 *THIS REPORT MUST NOT BE REPRODUCED EXCEPT IN FULL, WITHOUT THE WRITTEN APPROVAL OF THE LABORATORY. *TOTAL SAMPLE SIZE = ACC. + REJ.
 *NUTS HARDNESS: ONLY INSPECT THE 2 POINTS ON THE MIDDLE OF THE BEARING OF THE NUTS. (THE 2 POINTS MUST BE 180 DEGREE SEPARATELY) QE20E



SCANNED